

# 2025 Consumer Confidence Report for Public Water System STARR WSC

Public Water System ID: TX0910046

This is your water quality report for January 1 to December 31, 2025

STARR WSC provides groundwater from the Trinity Aquifer located in Grayson County Texas.

For more information regarding this report contact:

Name Chuck Dodd

Phone 903-465-9135

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (903) 465-9135.

## Definitions and Abbreviations

### Definitions and Abbreviations

The following tables contain scientific terms and measures, some of which may require explanation.

Action Level:

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

RAA

Running Annual Average.

LRAA

Locational Running Annual Average.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL

million fibers per liter (a measure of asbestos)

mrem:

millirems per year (a measure of radiation absorbed by the body)

na:

not applicable.

NTU

nephelometric turbidity units (a measure of turbidity)

pCi/L

picocuries per liter (a measure of radioactivity)

## Definitions and Abbreviations

ppb:	micrograms per liter or parts per billion (Also UG/L)
ppm:	milligrams per liter or parts per million
ppq	parts per quadrillion, or picograms per liter (pg/L)
ppt	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

## Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. STARR WSC is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact STARR WSC at 903-465-9135. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than 2 milligrams per liter (mg/L) of fluoride may develop cosmetic discoloration of their permanent teeth (dental fluorosis). The drinking water provided by your community water system Starr Water Supply Corporation has a fluoride concentration of 1.86 – 2.36 mg/L.

Dental fluorosis, in its moderate or severe forms, may result in a brown staining and/or pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under nine should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride-containing products. Older children and adults may safely drink the water. For more information, please call Chuck Dodd of Starr Water Supply Corporation at (903) 465-9135. Some home water treatment units are also available to remove fluoride from drinking water. To learn more about available home water treatment units, you may call NSF International at 1-877-8-NSF-HELP.

**Information about Source Water**

**Sources of Drinking Water**

STARR WSC is Ground water.

Our water source(s) and source water assessment information are listed below:

Source Name		Type of Water	Report Status	Location
1 - 6433 DRIPPING SPRING RD		Ground water		
2 - 2011 WHITNEY RD	WHITNEY	Ground water		
3 - 5800 DRIPPING SPRING RD	DRIPPING SPRING	Ground water		
4 - 934 CLEVE COLE RD	CLEVE COLE RD	Ground water		
5 - 221 BARBARA LN	221 BARBARA LN	Ground water		
6 - 1031 CLEVE COLE RD		Ground water		

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact Chuck Dodd of Starr Water Supply Corporation at (903) 465-9135.

## 2025 Water Quality Test Results

### Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Lead and Copper	Date Sampled	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results	Units	AL	Sites over AL	Violation	Likely Source of Contamination
Copper	08/07/2024	.1	0.0359 – 0.203	ppm	1.3	0	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	08/07/2024	0	0 – 1.02	ppb	15	0	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2024	4	3.6 - 3.6	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

\*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year

Total Trihalomethanes (TTHM)	2024	15	15.3 – 15.3	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
------------------------------	------	----	-------------	-----------------------	----	-----	---	--

\*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	11/17/2021	1.5	0 - 1.5	0	5	pCi/L	N	Erosion of natural deposits.
Gross alpha excluding radon and uranium	5/19/2021	4.1	0 – 4.1	0	15	pCi/L	N	Erosion of natural deposits.
Gross alpha including radon and uranium	5/19/2021	4.1	0 – 4.1	0	0	pCi/L	N	Erosion of natural deposits.
Gross Beta Particle Activity	11/17/2021	4.2	0 - 4.2	0	50	pCi/L*	N	Decay of natural and man-made deposits.

\*EPA considers 50 pCi/L to be the level of concern for beta particles.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	6/4/2024	0.028	0.011 – 0.028	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	6/04/2024	2.9	0 - 2.9	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Dibromochloromethane	6/24/2025	4.2	0 – 4.2	0.06	0	UG/L		
Fluoride	6/24/2025	2.36	1.86 - 2.36	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate - Nitrite	6/4/2024	0.065	0.0318 - 0.065	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Nitrate [measured as Nitrogen]	6/24/2025	.055	0.0392 – 0.055	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Volatile Organic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Xylenes	2023	0.00075	0 - 0.00075	10	10	ppm	N	Discharge from petroleum factories; Discharge from chemical factories.

#### Disinfectant Residual

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Free Chlorine	2025	1.12	0.32 – 2.08	4	4	ppm	No	Water additive used to control microbes.

### Lead Service Line Inventory

We would like to thank each one of you that helped us to complete our Lead Service Line Inventory. This report is required by the EPA and the State of Texas. The inventory has been completed and prepared for examination. This may be viewed at the Starr Water Office located at 1031 Cleve Cole Rd. Denison TX. During this process we did not discover any lead, lead lines, lines of unknown material, or galvanized lines needing replacement.

**MOST RECENT TESTING CONDUCTED**

Facility ID	Collection Date	Analyte Name	Detection Value	Exceeds MCL		Maximum Contaminant Level (MCL)
EP001	3/25/2026	1,1,1,2-TETRACHLOROETHANE	< 0.5 UG/L	N/A		
EP002	3/25/2026	1,1,1,2-TETRACHLOROETHANE	< 0.5 UG/L	N/A		
EP003	3/25/2026	1,1,1,2-TETRACHLOROETHANE	< 0.5 UG/L	N/A		
EP004	3/25/2026	1,1,1,2-TETRACHLOROETHANE	< 0.5 UG/L	N/A		
EP001	3/25/2026	1,1,1-TRICHLOROETHANE	< 0.5 UG/L	N	MG/L	0.2
EP002	3/25/2026	1,1,1-TRICHLOROETHANE	< 0.5 UG/L	N	MG/L	0.2
EP003	3/25/2026	1,1,1-TRICHLOROETHANE	< 0.5 UG/L	N	MG/L	0.2
EP004	3/25/2026	1,1,1-TRICHLOROETHANE	< 0.5 UG/L	N	MG/L	0.2
EP001	3/25/2026	1,1,2,2-TETRACHLOROETHANE	< 0.5 UG/L	N/A		
EP002	3/25/2026	1,1,2,2-TETRACHLOROETHANE	< 0.5 UG/L	N/A		
EP003	3/25/2026	1,1,2,2-TETRACHLOROETHANE	< 0.5 UG/L	N/A		
EP004	3/25/2026	1,1,2,2-TETRACHLOROETHANE	< 0.5 UG/L	N/A		
EP001	3/25/2026	1,1,2-TRICHLOROETHANE	< 0.5 UG/L	N	MG/L	0.005
EP002	3/25/2026	1,1,2-TRICHLOROETHANE	< 0.5 UG/L	N	MG/L	0.005
EP003	3/25/2026	1,1,2-TRICHLOROETHANE	< 0.5 UG/L	N	MG/L	0.005
EP004	3/25/2026	1,1,2-TRICHLOROETHANE	< 0.5 UG/L	N	MG/L	0.005
EP001	3/25/2026	1,1-DICHLOROETHANE	< 0.5 UG/L	N/A		
EP002	3/25/2026	1,1-DICHLOROETHANE	< 0.5 UG/L	N/A		
EP003	3/25/2026	1,1-DICHLOROETHANE	< 0.5 UG/L	N/A		
EP004	3/25/2026	1,1-DICHLOROETHANE	< 0.5 UG/L	N/A		
EP001	3/25/2026	1,1-DICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.007
EP002	3/25/2026	1,1-DICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.007
EP003	3/25/2026	1,1-DICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.007
EP004	3/25/2026	1,1-DICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.007
EP001	3/25/2026	1,1-DICHLOROPROPENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	1,1-DICHLOROPROPENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	1,1-DICHLOROPROPENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	1,1-DICHLOROPROPENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	1,2,3-TRICHLOROBENZENE	< 0.5 UG/L	N/A		

EP002	3/25/2026	1,2,3-TRICHLOROBENZENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	1,2,3-TRICHLOROBENZENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	1,2,3-TRICHLOROBENZENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	1,2,3-TRICHLOROPROPANE	< 0.02 UG/L	N/A		
EP001	3/25/2026	1,2,3-TRICHLOROPROPANE	< 0.5 UG/L	N/A		
EP002	3/25/2026	1,2,3-TRICHLOROPROPANE	< 0.02 UG/L	N/A		
EP002	3/25/2026	1,2,3-TRICHLOROPROPANE	< 0.5 UG/L	N/A		
EP003	3/25/2026	1,2,3-TRICHLOROPROPANE	< 0.02 UG/L	N/A		
EP003	3/25/2026	1,2,3-TRICHLOROPROPANE	< 0.5 UG/L	N/A		
EP004	3/25/2026	1,2,3-TRICHLOROPROPANE	< 0.02 UG/L	N/A		
EP004	3/25/2026	1,2,3-TRICHLOROPROPANE	< 0.5 UG/L	N/A		
EP001	3/25/2026	1,2,4-TRICHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.07
EP002	3/25/2026	1,2,4-TRICHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.07
EP003	3/25/2026	1,2,4-TRICHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.07
EP004	3/25/2026	1,2,4-TRICHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.07
EP001	3/25/2026	1,2,4-TRIMETHYLBENZENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	1,2,4-TRIMETHYLBENZENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	1,2,4-TRIMETHYLBENZENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	1,2,4-TRIMETHYLBENZENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	1,2-DIBROMO-3-CHLOROPROPANE	< 0.02 UG/L	N	MG/L	0.0002
EP002	3/25/2026	1,2-DIBROMO-3-CHLOROPROPANE	< 0.02 UG/L	N	MG/L	0.0002
EP003	3/25/2026	1,2-DIBROMO-3-CHLOROPROPANE	< 0.02 UG/L	N	MG/L	0.0002
EP004	3/25/2026	1,2-DIBROMO-3-CHLOROPROPANE	< 0.02 UG/L	N	MG/L	0.0002
EP001	3/25/2026	1,2-DICHLOROETHANE	< 0.5 UG/L	N	MG/L	0.005
EP002	3/25/2026	1,2-DICHLOROETHANE	< 0.5 UG/L	N	MG/L	0.005
EP003	3/25/2026	1,2-DICHLOROETHANE	< 0.5 UG/L	N	MG/L	0.005
EP004	3/25/2026	1,2-DICHLOROETHANE	< 0.5 UG/L	N	MG/L	0.005
EP001	3/25/2026	1,2-DICHLOROPROPANE	< 0.5 UG/L	N	MG/L	0.005
EP002	3/25/2026	1,2-DICHLOROPROPANE	< 0.5 UG/L	N	MG/L	0.005
EP003	3/25/2026	1,2-DICHLOROPROPANE	< 0.5 UG/L	N	MG/L	0.005
EP004	3/25/2026	1,2-DICHLOROPROPANE	< 0.5 UG/L	N	MG/L	0.005
EP001	3/25/2026	1,3,5-TRIMETHYLBENZENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	1,3,5-TRIMETHYLBENZENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	1,3,5-TRIMETHYLBENZENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	1,3,5-TRIMETHYLBENZENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	1,3-DICHLOROPROPANE	< 0.5 UG/L	N/A		

EP002	3/25/2026	1,3-DICHLOROPROPANE	< 0.5 UG/L	N/A		
EP003	3/25/2026	1,3-DICHLOROPROPANE	< 0.5 UG/L	N/A		
EP004	3/25/2026	1,3-DICHLOROPROPANE	< 0.5 UG/L	N/A		
EP001	3/25/2026	2,2-DICHLOROPROPANE	< 0.5 UG/L	N/A		
EP002	3/25/2026	2,2-DICHLOROPROPANE	< 0.5 UG/L	N/A		
EP003	3/25/2026	2,2-DICHLOROPROPANE	< 0.5 UG/L	N/A		
EP004	3/25/2026	2,2-DICHLOROPROPANE	< 0.5 UG/L	N/A		
EP001	3/25/2026	2,4,5-T	< 0.625 UG/L	N/A		
EP002	3/25/2026	2,4,5-T	< 0.625 UG/L	N/A		
EP003	3/25/2026	2,4,5-T	< 0.625 UG/L	N/A		
EP004	3/25/2026	2,4,5-T	< 0.625 UG/L	N/A		
EP001	3/25/2026	2,4,5-TP	< 0.2 UG/L	N	MG/L	0.05
EP002	3/25/2026	2,4,5-TP	< 0.2 UG/L	N	MG/L	0.05
EP003	3/25/2026	2,4,5-TP	< 0.2 UG/L	N	MG/L	0.05
EP004	3/25/2026	2,4,5-TP	< 0.2 UG/L	N	MG/L	0.05
EP001	3/25/2026	2,4-D	< 0.1 UG/L	N	MG/L	0.07
EP002	3/25/2026	2,4-D	< 0.1 UG/L	N	MG/L	0.07
EP003	3/25/2026	2,4-D	< 0.1 UG/L	N	MG/L	0.07
EP004	3/25/2026	2,4-D	< 0.1 UG/L	N	MG/L	0.07
EP001	3/25/2026	2,4-DB	< 2.5 UG/L	N/A		
EP002	3/25/2026	2,4-DB	< 2.5 UG/L	N/A		
EP003	3/25/2026	2,4-DB	< 2.5 UG/L	N/A		
EP004	3/25/2026	2,4-DB	< 2.5 UG/L	N/A		
EP001	3/25/2026	2-HEXANONE	< 5 UG/L	N/A		
EP002	3/25/2026	2-HEXANONE	< 5 UG/L	N/A		
EP003	3/25/2026	2-HEXANONE	< 5 UG/L	N/A		
EP004	3/25/2026	2-HEXANONE	< 5 UG/L	N/A		
EP001	3/25/2026	3-HYDROXYCARBOFURAN	< 1 UG/L	N/A		
EP002	3/25/2026	3-HYDROXYCARBOFURAN	< 1 UG/L	N/A		
EP003	3/25/2026	3-HYDROXYCARBOFURAN	< 1 UG/L	N/A		
EP004	3/25/2026	3-HYDROXYCARBOFURAN	< 1 UG/L	N/A		
EP001	3/25/2026	ACETONE	< 5 UG/L	N/A		
EP002	3/25/2026	ACETONE	< 5 UG/L	N/A		
EP003	3/25/2026	ACETONE	< 5 UG/L	N/A		
EP004	3/25/2026	ACETONE	< 5 UG/L	N/A		
EP001	3/25/2026	ACRYLONITRILE	< 5 UG/L	N/A		

EP002	3/25/2026	ACRYLONITRILE	< 5 UG/L	N/A		
EP003	3/25/2026	ACRYLONITRILE	< 5 UG/L	N/A		
EP004	3/25/2026	ACRYLONITRILE	< 5 UG/L	N/A		
EP001	3/25/2026	ALDICARB	< 0.5 UG/L	N	MG/L	0.003
EP002	3/25/2026	ALDICARB	< 0.5 UG/L	N	MG/L	0.003
EP003	3/25/2026	ALDICARB	< 0.5 UG/L	N	MG/L	0.003
EP004	3/25/2026	ALDICARB	< 0.5 UG/L	N	MG/L	0.003
EP001	3/25/2026	ALDICARB SULFONE	< 0.5 UG/L	N	MG/L	0.002
EP002	3/25/2026	ALDICARB SULFONE	< 0.5 UG/L	N	MG/L	0.002
EP003	3/25/2026	ALDICARB SULFONE	< 0.5 UG/L	N	MG/L	0.002
EP004	3/25/2026	ALDICARB SULFONE	< 0.5 UG/L	N	MG/L	0.002
EP001	3/25/2026	ALDICARB SULFOXIDE	< 0.5 UG/L	N	MG/L	0.004
EP002	3/25/2026	ALDICARB SULFOXIDE	< 0.5 UG/L	N	MG/L	0.004
EP003	3/25/2026	ALDICARB SULFOXIDE	< 0.5 UG/L	N	MG/L	0.004
EP004	3/25/2026	ALDICARB SULFOXIDE	< 0.5 UG/L	N	MG/L	0.004
EP001	3/25/2026	ALKALINITY, BICARBONATE	493 MG/L	N/A		
EP002	3/25/2026	ALKALINITY, BICARBONATE	< 0 MG/L	N/A		
EP003	3/25/2026	ALKALINITY, BICARBONATE	< 0 MG/L	N/A		
EP001	3/25/2026	ALKALINITY, CaCO3 STABILITY	3.36 MG/L	N/A		
EP002	3/25/2026	ALKALINITY, CaCO3 STABILITY	513 MG/L	N/A		
EP003	3/25/2026	ALKALINITY, CaCO3 STABILITY	468 MG/L	N/A		
EP001	3/25/2026	ALKALINITY, PHENOLPHTHALEIN	1.68 MG/L	N/A		
EP002	3/25/2026	ALKALINITY, PHENOLPHTHALEIN	7.8 MG/L	N/A		
EP003	3/25/2026	ALKALINITY, PHENOLPHTHALEIN	10.2 MG/L	N/A		
EP001	3/25/2026	ALKALINITY, TOTAL	497 MG/L	N/A		
EP002	3/25/2026	ALKALINITY, TOTAL	529 MG/L	N/A		
EP003	3/25/2026	ALKALINITY, TOTAL	489 MG/L	N/A		
EP001	3/25/2026	BAYGON	< 1 UG/L	N/A		
EP002	3/25/2026	BAYGON	< 1 UG/L	N/A		
EP003	3/25/2026	BAYGON	< 1 UG/L	N/A		
EP004	3/25/2026	BAYGON	< 1 UG/L	N/A		
EP001	3/25/2026	BENTAZON	< 2.5 UG/L	N/A		
EP002	3/25/2026	BENTAZON	< 2.5 UG/L	N/A		
EP003	3/25/2026	BENTAZON	< 2.5 UG/L	N/A		
EP004	3/25/2026	BENTAZON	< 2.5 UG/L	N/A		
EP001	3/25/2026	BENZENE	< 0.5 UG/L	N	MG/L	0.005

EP002	3/25/2026	BENZENE	< 0.5 UG/L	N	MG/L	0.005
EP003	3/25/2026	BENZENE	< 0.5 UG/L	N	MG/L	0.005
EP004	3/25/2026	BENZENE	< 0.5 UG/L	N	MG/L	0.005
EP001	3/25/2026	BROMOBENZENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	BROMOBENZENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	BROMOBENZENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	BROMOBENZENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	BROMOCHLOROMETHANE	< 0.5 UG/L	N/A		
EP002	3/25/2026	BROMOCHLOROMETHANE	< 0.5 UG/L	N/A		
EP003	3/25/2026	BROMOCHLOROMETHANE	< 0.5 UG/L	N/A		
EP004	3/25/2026	BROMOCHLOROMETHANE	< 0.5 UG/L	N/A		
EP001	3/25/2026	BROMODICHLOROMETHANE	< 1 UG/L	N/A		
EP002	3/25/2026	BROMODICHLOROMETHANE	< 1 UG/L	N/A		
EP003	3/25/2026	BROMODICHLOROMETHANE	< 1 UG/L	N/A		
EP004	3/25/2026	BROMODICHLOROMETHANE	< 1 UG/L	N/A		
EP004	6/24/2025	BROMODICHLOROMETHANE	1.18 UG/L	N/A		
EP001	3/25/2026	BROMOFORM	2.88 UG/L	N/A		
EP002	3/25/2026	BROMOFORM	2.49 UG/L	N/A		
EP003	3/25/2026	BROMOFORM	2.82 UG/L	N/A		
EP004	3/25/2026	BROMOFORM	2.97 UG/L	N/A		
EP001	3/25/2026	BROMOMETHANE	< 0.5 UG/L	N/A		
EP002	3/25/2026	BROMOMETHANE	< 0.5 UG/L	N/A		
EP003	3/25/2026	BROMOMETHANE	< 0.5 UG/L	N/A		
EP004	3/25/2026	BROMOMETHANE	< 0.5 UG/L	N/A		
EP001	3/25/2026	CARBARYL	< 1 UG/L	N/A		
EP002	3/25/2026	CARBARYL	< 1 UG/L	N/A		
EP003	3/25/2026	CARBARYL	< 1 UG/L	N/A		
EP004	3/25/2026	CARBARYL	< 1 UG/L	N/A		
EP001	3/25/2026	CARBOFURAN	< 0.5 UG/L	N	MG/L	0.04
EP002	3/25/2026	CARBOFURAN	< 0.5 UG/L	N	MG/L	0.04
EP003	3/25/2026	CARBOFURAN	< 0.5 UG/L	N	MG/L	0.04
EP004	3/25/2026	CARBOFURAN	< 0.5 UG/L	N	MG/L	0.04
EP001	3/25/2026	CARBON DISULFIDE	< 0.5 UG/L	N/A		
EP002	3/25/2026	CARBON DISULFIDE	< 0.5 UG/L	N/A		
EP003	3/25/2026	CARBON DISULFIDE	< 0.5 UG/L	N/A		
EP004	3/25/2026	CARBON DISULFIDE	< 0.5 UG/L	N/A		

EP001	3/25/2026	CARBON TETRACHLORIDE	< 0.5 UG/L	N	MG/L	0.005
EP002	3/25/2026	CARBON TETRACHLORIDE	< 0.5 UG/L	N	MG/L	0.005
EP003	3/25/2026	CARBON TETRACHLORIDE	< 0.5 UG/L	N	MG/L	0.005
EP004	3/25/2026	CARBON TETRACHLORIDE	< 0.5 UG/L	N	MG/L	0.005
EP001	3/25/2026	CHLORIDE	96.1 MG/L	N/A		
EP002	3/25/2026	CHLORIDE	64.8 MG/L	N/A		
EP003	3/25/2026	CHLORIDE	128 MG/L	N/A		
EP004	6/24/2025	CHLORIDE	58.4 MG/L	N/A		
EP001	3/25/2026	CHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.1
EP002	3/25/2026	CHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.1
EP003	3/25/2026	CHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.1
EP004	3/25/2026	CHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.1
EP001	3/25/2026	CHLOROETHANE	< 0.5 UG/L	N/A		
EP002	3/25/2026	CHLOROETHANE	< 0.5 UG/L	N/A		
EP003	3/25/2026	CHLOROETHANE	< 0.5 UG/L	N/A		
EP004	3/25/2026	CHLOROETHANE	< 0.5 UG/L	N/A		
EP001	3/25/2026	CHLOROFORM	< 1 UG/L	N/A		
EP002	3/25/2026	CHLOROFORM	< 1 UG/L	N/A		
EP003	3/25/2026	CHLOROFORM	< 1 UG/L	N/A		
EP004	3/25/2026	CHLOROFORM	< 1 UG/L	N/A		
EP001	3/25/2026	CHLOROMETHANE	< 0.5 UG/L	N/A		
EP002	3/25/2026	CHLOROMETHANE	< 0.5 UG/L	N/A		
EP003	3/25/2026	CHLOROMETHANE	< 0.5 UG/L	N/A		
EP004	3/25/2026	CHLOROMETHANE	< 0.5 UG/L	N/A		
EP001	3/25/2026	CIS-1,2-DICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.07
EP002	3/25/2026	CIS-1,2-DICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.07
EP003	3/25/2026	CIS-1,2-DICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.07
EP004	3/25/2026	CIS-1,2-DICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.07
EP001	3/25/2026	CIS-1,3-DICHLOROPROPENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	CIS-1,3-DICHLOROPROPENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	CIS-1,3-DICHLOROPROPENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	CIS-1,3-DICHLOROPROPENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	CONDUCTIVITY @ 25 C UMHOS/CM	1410 UMHO/CM	N/A		
EP002	3/25/2026	CONDUCTIVITY @ 25 C UMHOS/CM	1350 UMHO/CM	N/A		
EP003	3/25/2026	CONDUCTIVITY @ 25 C UMHOS/CM	1470 UMHO/CM	N/A		
EP004	6/24/2025	CONDUCTIVITY @ 25 C UMHOS/CM	1280 UMHO/CM	N/A		

EP001	3/25/2026	CYANIDE	< 0.02 MG/L	N/A		
EP002	3/25/2026	CYANIDE	< 0.02 MG/L	N/A		
EP003	3/25/2026	CYANIDE	< 0.02 MG/L	N/A		
EP004	3/25/2026	CYANIDE	< 0.02 MG/L	N/A		
EP001	3/25/2026	DALAPON	< 1 UG/L	N	MG/L	0.2
EP002	3/25/2026	DALAPON	< 1 UG/L	N	MG/L	0.2
EP003	3/25/2026	DALAPON	< 1 UG/L	N	MG/L	0.2
EP004	3/25/2026	DALAPON	< 1 UG/L	N	MG/L	0.2
DS01	6/24/2025	DIBROMOACETIC ACID	1 UG/L	N/A		
EP001	3/25/2026	DIBROMOCHLOROMETHANE	1.06 UG/L	N/A		
EP002	3/25/2026	DIBROMOCHLOROMETHANE	2.21 UG/L	N/A		
EP003	3/25/2026	DIBROMOCHLOROMETHANE	< 1 UG/L	N/A		
EP004	3/25/2026	DIBROMOCHLOROMETHANE	2.1 UG/L	N/A		
EP001	3/25/2026	DIBROMOMETHANE	< 0.5 UG/L	N/A		
EP002	3/25/2026	DIBROMOMETHANE	< 0.5 UG/L	N/A		
EP003	3/25/2026	DIBROMOMETHANE	< 0.5 UG/L	N/A		
EP004	3/25/2026	DIBROMOMETHANE	< 0.5 UG/L	N/A		
EP001	3/25/2026	DICAMBA	< 1.25 UG/L	N/A		
EP002	3/25/2026	DICAMBA	< 1.25 UG/L	N/A		
EP003	3/25/2026	DICAMBA	< 1.25 UG/L	N/A		
EP004	3/25/2026	DICAMBA	< 1.25 UG/L	N/A		
EP001	3/25/2026	DICHLORODIFLUOROMETHANE	< 0.5 UG/L	N/A		
EP002	3/25/2026	DICHLORODIFLUOROMETHANE	< 0.5 UG/L	N/A		
EP003	3/25/2026	DICHLORODIFLUOROMETHANE	< 0.5 UG/L	N/A		
EP004	3/25/2026	DICHLORODIFLUOROMETHANE	< 0.5 UG/L	N/A		
EP001	3/25/2026	DICHLOROMETHANE	< 0.5 UG/L	N	MG/L	0.005
EP002	3/25/2026	DICHLOROMETHANE	< 0.5 UG/L	N	MG/L	0.005
EP003	3/25/2026	DICHLOROMETHANE	< 0.5 UG/L	N	MG/L	0.005
EP004	3/25/2026	DICHLOROMETHANE	< 0.5 UG/L	N	MG/L	0.005
EP001	3/25/2026	DICHLORPROP	< 2.5 UG/L	N/A		
EP002	3/25/2026	DICHLORPROP	< 2.5 UG/L	N/A		
EP003	3/25/2026	DICHLORPROP	< 2.5 UG/L	N/A		
EP004	3/25/2026	DICHLORPROP	< 2.5 UG/L	N/A		
EP001	3/25/2026	DINOSEB	< 0.2 UG/L	N	MG/L	0.007
EP002	3/25/2026	DINOSEB	< 0.2 UG/L	N	MG/L	0.007
EP003	3/25/2026	DINOSEB	< 0.2 UG/L	N	MG/L	0.007

EP004	3/25/2026	DINOSEB	< 0.2 UG/L	N	MG/L	0.007
EP001	3/25/2026	ETHYL METHACRYLATE	< 5 UG/L	N/A		
EP002	3/25/2026	ETHYL METHACRYLATE	< 5 UG/L	N/A		
EP003	3/25/2026	ETHYL METHACRYLATE	< 5 UG/L	N/A		
EP004	3/25/2026	ETHYL METHACRYLATE	< 5 UG/L	N/A		
EP001	3/25/2026	ETHYLBENZENE	< 0.5 UG/L	N	MG/L	0.7
EP002	3/25/2026	ETHYLBENZENE	< 0.5 UG/L	N	MG/L	0.7
EP003	3/25/2026	ETHYLBENZENE	< 0.5 UG/L	N	MG/L	0.7
EP004	3/25/2026	ETHYLBENZENE	< 0.5 UG/L	N	MG/L	0.7
EP001	3/25/2026	ETHYLENE DIBROMIDE	< 0.01 UG/L	N	MG/L	0.00005
EP002	3/25/2026	ETHYLENE DIBROMIDE	< 0.01 UG/L	N	MG/L	0.00005
EP003	3/25/2026	ETHYLENE DIBROMIDE	< 0.01 UG/L	N	MG/L	0.00005
EP004	3/25/2026	ETHYLENE DIBROMIDE	< 0.01 UG/L	N	MG/L	0.00005
EP001	3/25/2026	FLUORIDE	1.88 MG/L	N	MG/L	4
EP002	3/25/2026	FLUORIDE	1.74 MG/L	N	MG/L	4
EP003	3/25/2026	FLUORIDE	1.6 MG/L	N	MG/L	4
EP004	6/24/2025	FLUORIDE	1.56 MG/L	N	MG/L	4
EP001	3/25/2026	HEXACHLOROBUTADIENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	HEXACHLOROBUTADIENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	HEXACHLOROBUTADIENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	HEXACHLOROBUTADIENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	HYDROXIDE AS CALCIUM CARBONATE	< 0 MG/L	N/A		
EP002	3/25/2026	HYDROXIDE AS CALCIUM CARBONATE	15.6 MG/L	N/A		
EP003	3/25/2026	HYDROXIDE AS CALCIUM CARBONATE	20.4 MG/L	N/A		
EP001	3/25/2026	ISOPROPYLBENZENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	ISOPROPYLBENZENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	ISOPROPYLBENZENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	ISOPROPYLBENZENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	M-DICHLOROBENZENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	M-DICHLOROBENZENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	M-DICHLOROBENZENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	M-DICHLOROBENZENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	METHIOCARB	< 1 UG/L	N/A		
EP002	3/25/2026	METHIOCARB	< 1 UG/L	N/A		
EP003	3/25/2026	METHIOCARB	< 1 UG/L	N/A		
EP004	3/25/2026	METHIOCARB	< 1 UG/L	N/A		

EP001	3/25/2026	METHOMYL	< 1 UG/L	N/A		
EP002	3/25/2026	METHOMYL	< 1 UG/L	N/A		
EP003	3/25/2026	METHOMYL	< 1 UG/L	N/A		
EP004	3/25/2026	METHOMYL	< 1 UG/L	N/A		
EP001	3/25/2026	METHYL ETHYL KETONE	< 5 UG/L	N/A		
EP002	3/25/2026	METHYL ETHYL KETONE	< 5 UG/L	N/A		
EP003	3/25/2026	METHYL ETHYL KETONE	< 5 UG/L	N/A		
EP004	3/25/2026	METHYL ETHYL KETONE	< 5 UG/L	N/A		
EP001	3/25/2026	METHYL IODINE	< 0.5 UG/L	N/A		
EP002	3/25/2026	METHYL IODINE	< 0.5 UG/L	N/A		
EP003	3/25/2026	METHYL IODINE	< 0.5 UG/L	N/A		
EP004	3/25/2026	METHYL IODINE	< 0.5 UG/L	N/A		
EP001	3/25/2026	METHYL ISOBUTYL KETONE	< 5 UG/L	N/A		
EP002	3/25/2026	METHYL ISOBUTYL KETONE	< 5 UG/L	N/A		
EP003	3/25/2026	METHYL ISOBUTYL KETONE	< 5 UG/L	N/A		
EP004	3/25/2026	METHYL ISOBUTYL KETONE	< 5 UG/L	N/A		
EP001	3/25/2026	METHYL METHACRYLATE	< 5 UG/L	N/A		
EP002	3/25/2026	METHYL METHACRYLATE	< 5 UG/L	N/A		
EP003	3/25/2026	METHYL METHACRYLATE	< 5 UG/L	N/A		
EP004	3/25/2026	METHYL METHACRYLATE	< 5 UG/L	N/A		
EP001	3/25/2026	METHYL TERT-BUTYL ETHER	< 0.5 UG/L	N/A		
EP002	3/25/2026	METHYL TERT-BUTYL ETHER	< 0.5 UG/L	N/A		
EP003	3/25/2026	METHYL TERT-BUTYL ETHER	< 0.5 UG/L	N/A		
EP004	3/25/2026	METHYL TERT-BUTYL ETHER	< 0.5 UG/L	N/A		
DS01	6/24/2025	MONOCHLOROACETIC ACID	1.8 UG/L	N/A		
EP001	3/25/2026	NAPHTHALENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	NAPHTHALENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	NAPHTHALENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	NAPHTHALENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	N-BUTYLBENZENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	N-BUTYLBENZENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	N-BUTYLBENZENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	N-BUTYLBENZENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	NITRATE	0.043 MG/L	N	MG/L	10
EP002	3/25/2026	NITRATE	0.055 MG/L	N	MG/L	10
EP003	3/25/2026	NITRATE	0.032 MG/L	N	MG/L	10

EP004	3/25/2026	NITRATE	0.055 MG/L	N	MG/L	10
EP001	3/25/2026	N-PROPYLBENZENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	N-PROPYLBENZENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	N-PROPYLBENZENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	N-PROPYLBENZENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	O-CHLOROTOLUENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	O-CHLOROTOLUENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	O-CHLOROTOLUENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	O-CHLOROTOLUENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	O-DICHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.6
EP002	3/25/2026	O-DICHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.6
EP003	3/25/2026	O-DICHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.6
EP004	3/25/2026	O-DICHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.6
EP001	3/25/2026	OXAMYL	< 1 UG/L	N	MG/L	0.2
EP002	3/25/2026	OXAMYL	< 1 UG/L	N	MG/L	0.2
EP003	3/25/2026	OXAMYL	< 1 UG/L	N	MG/L	0.2
EP004	3/25/2026	OXAMYL	< 1 UG/L	N	MG/L	0.2
EP001	3/25/2026	O-XYLENE	< 0.5 UG/L	N	MG/L	10
EP002	3/25/2026	O-XYLENE	< 0.5 UG/L	N	MG/L	10
EP003	3/25/2026	O-XYLENE	< 0.5 UG/L	N	MG/L	10
EP004	3/25/2026	O-XYLENE	< 0.5 UG/L	N	MG/L	10
EP001	3/25/2026	P-CHLOROTOLUENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	P-CHLOROTOLUENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	P-CHLOROTOLUENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	P-CHLOROTOLUENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	P-DICHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.075
EP002	3/25/2026	P-DICHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.075
EP003	3/25/2026	P-DICHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.075
EP004	3/25/2026	P-DICHLOROBENZENE	< 0.5 UG/L	N	MG/L	0.075
EP001	3/25/2026	PENTACHLOROPHENOL	< 0.04 UG/L	N	MG/L	0.001
EP002	3/25/2026	PENTACHLOROPHENOL	< 0.04 UG/L	N	MG/L	0.001
EP003	3/25/2026	PENTACHLOROPHENOL	< 0.04 UG/L	N	MG/L	0.001
EP004	3/25/2026	PENTACHLOROPHENOL	< 0.04 UG/L	N	MG/L	0.001
EP001	3/25/2026	PICLORAM	< 0.1 UG/L	N	MG/L	0.5
EP002	3/25/2026	PICLORAM	< 0.1 UG/L	N	MG/L	0.5
EP003	3/25/2026	PICLORAM	< 0.1 UG/L	N	MG/L	0.5

EP004	3/25/2026	PICLORAM	< 0.1 UG/L	N	MG/L	0.5
EP001	3/25/2026	P-ISOPROPYLTOLUENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	P-ISOPROPYLTOLUENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	P-ISOPROPYLTOLUENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	P-ISOPROPYLTOLUENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	SEC-BUTYLBENZENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	SEC-BUTYLBENZENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	SEC-BUTYLBENZENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	SEC-BUTYLBENZENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	STYRENE	< 0.5 UG/L	N	MG/L	0.1
EP002	3/25/2026	STYRENE	< 0.5 UG/L	N	MG/L	0.1
EP003	3/25/2026	STYRENE	< 0.5 UG/L	N	MG/L	0.1
EP004	3/25/2026	STYRENE	< 0.5 UG/L	N	MG/L	0.1
EP001	3/25/2026	SULFATE	75.2 MG/L	N/A		
EP002	3/25/2026	SULFATE	78.8 MG/L	N/A		
EP003	3/25/2026	SULFATE	77.8 MG/L	N/A		
EP004	6/24/2025	SULFATE	85.7 MG/L	N/A		
EP001	3/25/2026	TDS	819 MG/L	N/A		
EP002	3/25/2026	TDS	803 MG/L	N/A		
EP003	3/25/2026	TDS	863 MG/L	N/A		
EP004	6/24/2025	TDS	793 MG/L	N/A		
EP001	3/25/2026	TERT-BUTYLBENZENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	TERT-BUTYLBENZENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	TERT-BUTYLBENZENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	TERT-BUTYLBENZENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	TETRACHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.005
EP002	3/25/2026	TETRACHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.005
EP003	3/25/2026	TETRACHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.005
EP004	3/25/2026	TETRACHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.005
EP001	3/25/2026	TETRAHYDROFURAN	< 5 UG/L	N/A		
EP002	3/25/2026	TETRAHYDROFURAN	< 5 UG/L	N/A		
EP003	3/25/2026	TETRAHYDROFURAN	< 5 UG/L	N/A		
EP004	3/25/2026	TETRAHYDROFURAN	< 5 UG/L	N/A		
EP001	3/25/2026	TOLUENE	< 0.5 UG/L	N	MG/L	1
EP002	3/25/2026	TOLUENE	< 0.5 UG/L	N	MG/L	1
EP003	3/25/2026	TOLUENE	< 0.5 UG/L	N	MG/L	1

EP004	3/25/2026	TOLUENE	< 0.5 UG/L	N	MG/L	1
DS01	6/24/2025	TOTAL HALOACETIC ACIDS (HAA5)	.0028 MG/L	N	MG/L	0.06
EP001	3/25/2026	TRANS-1,2-DICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.1
EP002	3/25/2026	TRANS-1,2-DICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.1
EP003	3/25/2026	TRANS-1,2-DICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.1
EP004	3/25/2026	TRANS-1,2-DICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.1
EP001	3/25/2026	TRANS-1,2-DICHLOROPROPENE	< 0.5 UG/L	N/A		
EP002	3/25/2026	TRANS-1,2-DICHLOROPROPENE	< 0.5 UG/L	N/A		
EP003	3/25/2026	TRANS-1,2-DICHLOROPROPENE	< 0.5 UG/L	N/A		
EP004	3/25/2026	TRANS-1,2-DICHLOROPROPENE	< 0.5 UG/L	N/A		
EP001	3/25/2026	TRICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.005
EP002	3/25/2026	TRICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.005
EP003	3/25/2026	TRICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.005
EP004	3/25/2026	TRICHLOROETHYLENE	< 0.5 UG/L	N	MG/L	0.005
EP001	3/25/2026	TRICHLOROFLUOROMETHANE	< 0.5 UG/L	N/A		
EP002	3/25/2026	TRICHLOROFLUOROMETHANE	< 0.5 UG/L	N/A		
EP003	3/25/2026	TRICHLOROFLUOROMETHANE	< 0.5 UG/L	N/A		
EP004	3/25/2026	TRICHLOROFLUOROMETHANE	< 0.5 UG/L	N/A		
DS01	6/24/2025	TTHM	.00502 MG/L	N	MG/L	0.08
EP001	3/25/2026	VINYL ACETATE	< 5 UG/L	N/A		
EP002	3/25/2026	VINYL ACETATE	< 5 UG/L	N/A		
EP003	3/25/2026	VINYL ACETATE	< 5 UG/L	N/A		
EP004	3/25/2026	VINYL ACETATE	< 5 UG/L	N/A		
EP001	3/25/2026	VINYL CHLORIDE	< 0.5 UG/L	N	MG/L	0.002
EP002	3/25/2026	VINYL CHLORIDE	< 0.5 UG/L	N	MG/L	0.002
EP003	3/25/2026	VINYL CHLORIDE	< 0.5 UG/L	N	MG/L	0.002
EP004	3/25/2026	VINYL CHLORIDE	< 0.5 UG/L	N	MG/L	0.002
EP001	3/25/2026	XYLENE, META AND PARA	< 0.5 UG/L	N/A		
EP002	3/25/2026	XYLENE, META AND PARA	< 0.5 UG/L	N/A		
EP003	3/25/2026	XYLENE, META AND PARA	< 0.5 UG/L	N/A		
EP004	3/25/2026	XYLENE, META AND PARA	< 0.5 UG/L	N/A		
EP001	3/25/2026	XYLENES, TOTAL	< 0.5 UG/L	N	MG/L	10
EP002	3/25/2026	XYLENES, TOTAL	< 0.5 UG/L	N	MG/L	10
EP003	3/25/2026	XYLENES, TOTAL	< 0.5 UG/L	N	MG/L	10
EP004	3/25/2026	XYLENES, TOTAL	< 0.5 UG/L	N	MG/L	10